

Fast lifetime

A method for estimating the average lifetime, calculated non-distinctive on different exponentials in a simple single path calculation, compared to a complete fitting operation against a more complex, non-linear model. Often used with [FLIM](#) go get a first idea of the lifetime distribution in the image.

In detail, FastLT is calculating the barycentre of the (pseudo-)pixel's decay. The time span from the barycentre of the IRF to the barycentre of the decay equals the average lifetime. This estimate is very fast and does not suffer as much from low statistics. If an [IRF](#) is not available, the "time zero" t_{θ} has to be estimated differently, for example by using the rising flank of the decay or the entrance of the [FWHM](#) interval. However, this may introduce a systematic shift in the estimated average lifetimes.

Copyright of this document belongs to PicoQuant GmbH. No parts of it may be reproduced, translated or transferred to third parties without written permission of PicoQuant GmbH. All information given here is reliable to our best knowledge. However, no responsibility is assumed for possible inaccuracies or omissions. Specifications and external appearances are subject to change without notice.



PicoQuant GmbH
Rudower Chaussee 29 (IGZ)
12489 Berlin
Germany

P +49-(0)30-1208820-89
F +49-(0)30-1208820-90
info@picoquant.com
www.picoquant.com